



**City of Missoula, Montana
City Council Committee Agenda Item**

Committee: Public Works and Mobility

Item: Professional Services Agreement with Woith Engineering for the 5th Street water main replacement

Date: July 20, 2022

Sponsor(s): Triston Firth

Prepared by: Ashley Strayer

Ward(s) Affected:

<input type="checkbox"/> Ward 1	<input type="checkbox"/> Ward 4
<input type="checkbox"/> Ward 2	<input type="checkbox"/> Ward 5
<input type="checkbox"/> Ward 3	<input type="checkbox"/> Ward 6
<input type="checkbox"/> All Wards	<input type="checkbox"/> N/A

Action Required:

Approve the Professional Services Agreement with Woith Engineering for the 5th Street Water Main Replacement from Garfield Street to Russell Street.

Recommended Motion(s):

I move the City Council: Approve and authorize the Mayor to sign a professional services agreement with Woith Engineering for the 5th Street Water Main replacement at a cost not to exceed \$109,404.00.

Timeline:

Committee discussion:	July 27, 2022
Council action (or sets hearing):	August 1, 2022
Public Hearing (if required):	N/A
Final Consideration	N/A
Deadline:	N/A

Background and Alternatives Explored:

Public Works & Mobility is proposing to enter into a Professional Services Agreement with Woith Engineering, Inc. to design and perform construction administration for the replacement of water mains in 5th St from just west of Garfield Street to Russell Street; This project will connect to a 6" Steel water main on the west side and a 6" Kalmein main on the east side just outside of Russell St ROW with anticipation that we would replace the rest of the existing Kalmein with future MDT Russell surface project. This project will replace approximately 1570 linear feet of 6" Kalmein water main from 1924. The pipes age makes this a priority 1 replacement project. We are also planning ahead of the Street Division knowing they plan on repaving the surface after the new water main is constructed.

Financial Implications:

\$109,404.00 from the Water Enterprise Fund

Links to external websites:

N/A